



Water System Overview


Taiwan Delegation
October 8, 2019

Simon Hsu
Water Resources Division



ladwp.com

LADWP TODAY



- Service area (472 sq.mi. or 1,222 Sq. Km.)
- Provide Water and Power to over 4 million people every day
- Over 467 million gallons of water delivered per day – 523,100 acre-feet per year (1.77 billion liters per day, 645 MCM per year)

* 1 AF = 1233.5 M³

ladwp.com



Infrastructure

- 111 Pressure zones
- 7,336 miles of pipeline (11,800 Km)
- 209,800 gate valves
- 60,900 fire hydrants
- 740,000 service connections




6,773 miles from LA to Taipei (10,900 Km)

ladwp.com



ladwp.com

LOS ANGELES' WATER SUPPLIES




ladwp.com

WATER SUPPLY & RELIABILITY CHALLENGES



ladwp.com

WATER RESOURCES PLANNING AND DEVELOPMENT HAS TRANSFORMED LA




WATER RESOURCES PLANNING AND DEVELOPMENT HAS TRANSFORMED LA



PURPOSE OF UWMP

- **Water Supply Reliability to Year 2040**
 - 2015 UWMP available for download at: www.ladwp.com/2015UWMP
- **Urban Water Management Planning Act (1984)**
 - Required for agencies serving more than 3,000 customers or 3,000 AFY (3.7 MCM per year)
- **State Grant/Loan Eligibility**



9

ladwp.com

URBAN WATER MANAGEMENT PLAN




Recycle 100% of Waste Water by 2035


Source 70% of all water locally by 2035

Reduce Potable Water Use
22.5% By 2025 **25%** By 2035

WATER SUPPLY RELIABILITY




LOCAL WATER SUPPLY PROGRAM



ladwp.com

HISTORICAL WATER SUPPLY FOR THE DEPARTMENT



LOCAL SUPPLY DEVELOPMENT CONSERVATION



RESIDENTIAL AND COMMERCIAL CONSERVATION REBATES



LOCAL SUPPLY DEVELOPMENT STORMWATER CAPTURE

Centralized
Dam Improvements
Spreading Basins

Distributed
Dry Wells
Cisterns
Green Streets
Rain Barrels

LA DWP ladwp.com

TUJUNGA SPREADING GROUNDS ENHANCEMENT PROJECT

As of September 2019


- Basin Improvements Completed
- New Intakes in Late 2019
- Open Space Starting Early 2020
- Project Completion in Early 2021

- Doubling stormwater capture capacity to 16,000 acre-feet to recharge the groundwater basin annually
- Increase stormwater diversion from the flood control channel for peak flow attenuation and downstream flood mitigation
- Provide community open space, neighborhood greening, and passive recreational space
- Improve water quality in the downstream water receiving bodies.
- Project Cost- \$50.4M
- Cost-benefit - \$85/AF

LA DWP ladwp.com

SF GROUNDWATER BASIN REMEDIATION

Planned groundwater basin remediation will be crucial to restoring the health and beneficial uses of the San Fernando Basin




NORTH HOLLYWOOD WEST WELLHEAD TREATMENT FACILITY

- Type of Proposed Treatment:**
 - 1,4-Dioxane Treatment using AOP w/LPGAC
- Construction: STARTED - 55% Complete**
 - September 2017 - September 2020
 - LADWP Construction Forces
- Submitted Steps 1-4 of DDW's 97-005 Policy Permitting Process**



LA DWP ladwp.com

LOCAL SUPPLY DEVELOPMENT RECYCLED WATER




NEW RECYCLED WATER INITIATIVE AT HYPERION

Program Objective:
Recycle 100% of available treated wastewater for beneficial reuse from the Hyperion Water Reclamation Plant by 2035.




LA DWP

RECYCLED WATER PROGRAM AT HWRP



Potential Regional Program Components



SEISMIC RISK TO IMPORTED SUPPLIES



25 ladwp.com

SEISMIC RESPONSE (MWD)

- MWD's Diamond Valley Lake, SWP terminal reservoir storage, and member-agency emergency storage can adequately provide for a 6-month supply of water with a temporary 25% reduction in demand.
- Emergency storage in Castaic and Pyramid Lakes can deliver water into LA's west San Fernando Valley, Calleguas, and Las Virgenes if SWP and LAA are severed. If these emergency sources are cut off, 50 cfs (1.4 cms) of CRA water could be moved through MWD's system to serve these areas until repairs could be made.
- On-call contractors working around the clock could be deployed to repair seismic damage in as short as a two-week time period.




ladwp.com

SEISMIC RESPONSE (LADWP)

- If the LAA is severed, LADWP will use Bouquet Reservoir to provide water to the City while repairs are made.
- In addition, if the California Aqueduct is intact south of the Neenach Pump Station (1st LAA – SWP Connection), arrangements may be made to transfer LAA water into the California Aqueduct for delivery to MWD. Arrangements can then be made to deliver water to the City through MWD's connections.



ladwp.com



ladwp.com

THANK YOU



CUSTOMERS FIRST



ladwp.com



Strengthening the Distribution System *with* Earthquake Resistant Pipes

LADWP Water Distribution Division
Genevieve Han P.E. & Martin Lam P.E.
Tuesday, October 8, 2019



ladwp.com

Presentation Outline

- LADWP Water Distribution System
- Water System Vulnerability
- Seismic Resilient Pipe Network
- EQ Pipe Evaluation Process
 - Planning
 - Design
 - Procurement
 - Construction
- Challenges
- Lessons Learned
- Future Goals




ladwp.com

LADWP Water Distribution System

- 5 Water Operating Districts
- 465 square miles (1,204 km²)
- 2,806 large valves
- 60,902 fire hydrants
- 732,350 service connections
- 7,337 miles of pipeline (11,808 km)




7,490 miles from LA to Sydney




ladwp.com

Water System Vulnerability




ladwp.com

Seismic Resilient Pipe Network (SRPN)



Seismic Resilient Pipe Network




ladwp.com



ladwp.com

Earthquake Pipe Evaluation



ladwp.com

Research

Available Products



ladwp.com

Research

Standard – ISO 16134

INTERNATIONAL STANDARD ISO 16134
Earthquake and subsidence-resistance design of ductile iron pipelines.

	CLASS	COMPONENT PERFORMANCE
Expansion/Contraction Performance (Elongation)	S1	± 1% L or more
	S2	± 0.5% L to ± 1% of L
	S3	Less than ± 0.5% of L
Pull Apart Resistance	A	17,000 l lbs +
	B	8,500 l lbs – 17,000 l lbs
	C	4,250 l lbs – 8,500 l lbs
	D	Less than 4,250 l lbs
Joint Deflection Angle	M1	15° or more
	M2	7.5° < 15°
	M3	Less than 7.5°

*L is the component length in inches
d is the nominal pipe diameter in inches



ISO: International Organization for Standardization

ladwp.com

Research

- Different vendors
- Review performance results
- Compatibility with existing system
- Material lead time
- Costs
- Special tools for construction




ladwp.com

Planning

Selection Criteria

- Pipe network serves critical facilities
- Historic leaks and pipe age
- Pipe network is within or adjacent to a fault or liquefaction zone
- Direct trunk line connections




Reseda Blvd ERDIP Project (Kubota)



Mission Hills ERDIP Project (American Pipe)

Design

- Start with traditional DI design
- Convert design to an ERDIP shop drawing



ladwp.com

Construction

USA, Layout, Sawcut, Shoring

Install the mainline

Polyethylene Encasement

Slurry as pipe is installed

CLEAN WATER PROJECT UNDERWAY
Clean & healthy water means it's safe to drink and it's good for the environment. The project you're building should be designed with clean water in mind. Use clean water for everything you can. Use clean water for everything you can. Use clean water for everything you can.

Chlorinate

Pave

Reconnect services, hydrants & connections to existing system



ladwp.com

Construction

Connections to Existing System

AWWA (Existing pipeline)

New ERDIP Pipe line

AWWA/JWWA Adaptor

Coupling DI

ERDIP Coupling DI

ERDIP Flanged Spigot Adaptor

AWWA Flange Bell Adaptor



ladwp.com

Construction

- Easy Installation
- S1, A, M2 (8-inch pipe)
- Compatible with existing materials
- Established material supply chain
- Requires welders



ladwp.com

American Earthquake Joint System

PERFORMANCE SPECS

SIZE (IN)	PIPE JOINT DEFLECTION (DEGREES)	CASTING JOINT DEFLECTION (DEGREES)	COMBINED ASSEMBLY DEFLECTION (DEGREES)	EXPANSION OR CONTRACTION FROM MID-POINT	DEAD-END THRUST RESISTANCE (LBS)	EQ CASTING ISO PERFORMANCE
6	5	3	8	± 2.4"	102,000	A, S1, M2
8	5	3	8	± 2.4"	136,000	A, S1, M2
12	5	3	8	± 2.4"	204,000	A, S1, M2
16	5	2	7	± 2.4"	272,000	A, S1, M3
20	4	2	6	± 2.4"	340,000	A, S1, M3
24	4	2	6	± 2.4"	408,000	A, S1, M3



American Flex-Ring Restrained Joint Ductile Iron Pipe and Fittings



PERFORMANCE SPECS - AMERICAN FLEX-RING® JOINT EARTHQUAKE CAPACITY

SIZE (IN)	NOMINAL LAY LENGTH (IN)	RADIUS OF CURVATURE (LINEAR FT)	MINIMUM PULL APART RESISTANCE (LBS)	JOINT DEFLECTION (DEGREES)	ELONGATION AT FULL INSERTION ASSEMBLY	ISO 1574 DESIGNATION
4	229 (9'-11")	230	68,000	3.00	+0.3% (0.75")	A, M3, S3
6	239 (9'-11")	230	102,000	5.00	+0.3% (0.75")	A, M3, S3
8	239 (9'-11")	230	136,000	5.00	+0.3% (0.75")	A, M3, S3
10	238 (9'-10")	230	170,000	5.00	+0.32% (0.75")	A, M3, S3
12	238 (9'-10")	230	204,000	5.00	+0.32% (0.75")	A, M3, S3
14	238 (9'-10")	285	238,000	4.00	+0.53% (1.25")	A, M3, S2
16	237.5 (9'-9.5")	305	272,000	3.75	+0.53% (1.25")	A, M3, S2
18	237 (9'-9")	305	306,000	3.75	+0.53% (1.25")	A, M3, S2
20	237 (9'-9")	327	340,000	3.50	+0.53% (1.25")	A, M3, S2
24	237 (9'-9")	380	408,000	3.00	+0.53% (1.25")	A, M3, S2
30	236.75 (9'-8.75")	468	510,000	2.50	+0.53% (1.25")	A, M3, S2
36	236.75 (9'-8.75")	570	612,000	2.00	+0.53% (1.25")	A, M3, S2
42	236.75 (9'-8.75")	570	714,000	2.00	+0.53% (1.25")	A, M3, S2
48	235.75 (9'-7.75")	570	816,000	2.00	+0.53% (1.25")	A, M3, S2
54	235.75 (9'-7.75")	570	918,000	1.50	+0.53% (1.25")	A, M3, S2



ladwp.com

American Flex-Lok Ball Joint

PERFORMANCE SPECS - AMERICAN FLEX-LOK® JOINT EARTHQUAKE CAPACITY

SIZE (IN)	NOMINAL LAY LENGTH (IN)	RADIUS OF CURVATURE (LINEAR FT)	MINIMUM PULL APART RESISTANCE (LBS)	JOINT DEFLECTION (DEGREES)	ELONGATION AT FULL INSERTION ASSEMBLY	ISO 1574 DESIGNATION
4	258 (21'-6")	48	68,000	25.00	+0.68% (1.75")	A, M1, S2
6	259 (21'-7")	49	102,000	25.00	+0.68% (1.75")	A, M1, S2
8	260 (21'-8")	49	136,000	25.00	+0.68% (1.75")	A, M1, S2
10	259.63 (21'-7.63")	49	170,000	25.00	+0.68% (1.75")	A, M1, S2
12	266.63 (21'-8.63")	49	204,000	25.00	+0.68% (1.75")	A, M1, S2
14	246 (20'-6")	78	238,000	15.00	+0.9% (2.25")	A, M1, S3
16	247.25 (20'-7.25")	52	272,000	32.50	+1.0% (2.25")	A, M1, S3
18	246 (20'-6")	78	306,000	15.00	+0.9% (2.25")	A, M1, S3
20	247.25 (20'-7.25")	53	340,000	22.00	+1.0% (2.25")	A, M1, S3
24	246 (20'-6")	55	408,000	21.00	+1.80% (4.50")	A, M1, S1
30	259 (21'-7")	82	255,000	15.00	+0.77% (2.00")	A, M1, S2
36	265 (22'-1")	84	612,000	15.00	+0.75% (2.00")	A, M1, S2

FLEX-LOK ADVANTAGES


- Ideal for joints adjacent to structures and areas subject to significant displacement
- Boltless joint designed for 15-degree or greater universal deflection



American Flex-Lok Ball Joint


PERFORMANCE SPECS - COMBINED ALLOWABLE DEFLECTION

DIAMETER (IN)	WORKING PRESSURE (PSI)	COMBINED ALLOWABLE DEFLECTION (DEGREES)	NORMAL MIDPOINT LAY LENGTH	MINIMUM MIDPOINT LAY LENGTH	COMBINED CONTRACTION OR ELONGATION AT MIDPOINT ASSEMBLY (IN)	MINIMUM PULL APART RESISTANCE (LBS)	ISO 1574 DESIGNATION
6	250	33.0	23'-1.81"	6'-9"	±3.65	102,000	A, M1, S1
8	250	33.0	23'-3.16"	6'-10"	±3.65	136,000	A, M1, S1
12	250	33.0	23'-5.48"	7'-2"	±3.65	204,000	A, M1, S1
16	250	28.5	24'-2.23"	8'-5"	±4.4	272,000	A, M1, S1
20	250	28.0	24'-3.60"	8'-7"	±4.4	340,000	A, M1, S1
24	250	27.0	24'-11.50"	9'-3"	±5.28	408,000	A, M1, S1



ladwp.com


American ERDIP Design



ladwp.com

Design Challenges

- High learning curve (limited/no experience with ERDIP designs)
- Restrained length calculations
 - Location identification for restraint (such as use of liners)
- Joint types and locations
- Expansion/contraction presets
- Deflection presets
- Compatibility with existing system



ladwp.com

Construction Challenges

- High learning curve (slower lay rate)
- Different joints and fittings compared to traditional ductile iron pipe
- Re-establishing pipe projection
 - Cut pipes: spigot ring method (slow process) vs. use of P-links (additional measurements)
- Substructures – vertical and horizontal offsets (material availability)
- Changes in field conditions – how do they affect the restrained lengths
- Quality control documents (tedious)
- Tools - extras



ladwp.com

Lessons Learned


- Design/Construction
 - Substructure research (use of Ground Penetrating Radar)
 - Restrained length calculations
 - Options for the crew if there are changes during construction due to unforeseen substructures
- Material procurement
 - Account for extras for unforeseen field conditions
 - Order additional materials for leak repairs
 - Order service saddles that are compatible with ERDIP pipe diameter
 - Order extra tools
- Construction
 - Unforeseen utilities required improvised changes in design during construction
 - Measureable evaluation metrics for construction



ladwp.com

ERDIP Mainline Projects

DISK#	ID	PROJECT	ERDIP FEET	FOOTAGE	PIPE SIZE (IN)	STATUS
1	1	Coliseum St	Kubota	1,400	18"	STARTED CONCT. (01/23)
2	2	Wentworth St	Kubota	1,500	18"	STARTED CONCT. (01/23)
3	3	Basin St	Kubota	1,500	18"	STARTED CONCT. (01/23)
4	4	Conroy St	Kubota	1,500	18"	STARTED CONCT. (01/23)
5	5	Beaver & Tricon	Kubota	4,500	18"	STARTED CONCT. (01/23)
6	6	Wentworth Blvd	Kubota	1,500	18"	STARTED CONCT. (01/23)
7	7	Coliseum St	Kubota	1,500	18"	STARTED CONCT. (01/23)
8	8	Wentworth Ave	Kubota	2,400	18"	STARTED CONCT. (01/23)
9	9	Bluff Pt & Basin St	Kubota	2,400	18"	STARTED CONCT. (01/23)
10	10	75th St & Basin St	Kubota	4,500	18"	STARTED CONCT. (01/23)
11	11	Basin St	Kubota	1,500	18"	STARTED CONCT. (01/23)
12	12	Wentworth Blvd	Kubota	1,500	18"	STARTED CONCT. (01/23)
13	13	Stratford Ave	US Pipe	1,500	18"	STARTED CONCT. (01/23)
14	14	Foot Hill Blvd	Kubota	11,500	18"	STARTED CONCT. (01/23)
15	15	DM Sully Blvd	Kubota	3,000	18"	STARTED CONCT. (01/23)
16	16	Southwest and San Fernando	Aluminum	4,500	18"	STARTED CONCT. (01/23)
17	17	Mission Rd	Kubota	4,500	18"	STARTED CONCT. (01/23)
18	18	Wentworth Blvd	Kubota	4,500	18"	STARTED CONCT. (01/23)
			Total =	74,500	(164 MILES)	



ladwp.com

Future Plans & Goals

- Improve quality control process
- Develop Design Criteria and Construction standards for earthquake resistant pipe
- Continue working with manufacturers to improve their products
- Continue promoting technologies and innovation
- Develop a Seismic Resilient Pipe Network (SRPN)



CUSTOMERS FIRST



ladwp.com




ladwp.com



Metropolitan's System Reliability Strategy

Member Agency Manager's Meeting August 23, 2019


Who Are We?



The Metropolitan Water District of Southern California, is a regional water wholesaler that provides water for 26 member public agencies living in six counties across a 5,200 square-mile service area. The district imports water from the Colorado River and Northern California to supplement local supplies and helps its members develop increased water conservation, recycling, storage and other resource management programs.

Member Agency Manager's Meeting August 23, 2019

Metropolitan Water District




Water Wholesaler
 19 Million People
 26 Members Agencies
 5,200 Square Miles
 4 MAF Annual Demand

MWD Service Area

Member Agency Manager's Meeting August 23, 2019


Southern California Imported Water Supply



MWD Service Area

Member Agency Manager's Meeting August 23, 2019

Metropolitan's Imported Water Supply



MWD Service Area

Member Agency Manager's Meeting August 23, 2019


Southern California Water Supplies



Total Demands	4 MAF
Remaining Need	2 MAF
Los Angeles Aqueduct	0.25 MAF (10 yr Average)
Groundwater, Recycled, Other Local	~1.75 MAF

Member Agency Manager's Meeting August 23, 2019

Metropolitan Makes up the Difference for Southern CA




SWP	1.33 MAF (10 yr Average)
CRA	0.73 MAF (10 yr Average)
Remaining Need	2 MAF

Member Agency Manager's Meeting August 23, 2019

Southern California's Water Portfolio

- 25% Colorado River
- 30% State Water Project supplies from Bay/Delta
- 45% Local
 - Los Angeles Aqueduct
 - Groundwater recovery
 - Recycling
 - Desalination
- + Conservation



Member Agency Manager's Meeting August 23, 2019

Purpose of Meeting

- Present Metropolitan’s strategy to maintain overall system reliability specifically seismic reliability
 - Components of reliability
 - Activities and studies

Member Agency Manager’s Meeting August 23, 2019

System Reliability Strategy

A hierarchical diagram with 'System Reliability' at the top in an orange box. Below it are five green boxes: 'Water Supply', 'System Capacity', 'Infrastructure Reliability', 'System Flexibility', and 'Emergency Response', all connected by lines to the top box.

- Developed as part of 2007 Integrated Area Study
- Collaborative effort between Metropolitan and member agencies

Member Agency Manager’s Meeting August 23, 2019

1. Water Supply Reliability

Develop and maintain an adequate water supply portfolio to meet full-service retail demands under all foreseeable hydrologic conditions

- Integrated Water Resources Plan (IRP)
 - Board Adopted
 - 1996, 2004, 2010, 2015
- 2015 IRP Findings
 - Diversify water portfolio
 - Invest in imported and local water supplies and conservation
 - Stabilize imported supplies
 - Local water supply target of 2.4 million acre-feet by 2040

Member Agency Manager’s Meeting August 23, 2019

Example: Regional Recycled Water Program

- Development of new regional water source
- Up to 150 MGD (168,000 AFY)
- Augment regional supplies during normal, drought, and emergency conditions
- Reduced frequency and magnitude of supply allocations

DEMONSTRATION PLANT AT JWPCP

Member Agency Manager’s Meeting August 23, 2019

2. System Capacity

Develop facilities to convey, treat, and distribute supplies to meet firm demands under peak condition

- System Overview Study
 - 2004 Report
- Integrated Area Study
 - 2007 Report
- Hydraulic Modeling
- Capital Investment Plan

F.E. WEYMOUTH WATER TREATMENT PLANT

Member Agency Manager’s Meeting August 23, 2019

Example: Inland Feeder & Diamond Valley Lake

- Inland Feeder
 - More than doubled water delivery capacity from SWP East Branch
 - Improved SWP/CRA blends
- Diamond Valley Lake
 - Nearly doubled in-region surface storage
 - Increased emergency storage capacity

ARROWHEAD TUNNELS BORING MACHINES

DIAMOND VALLEY LAKE WEST DAM & FOREBAY

Member Agency Manager’s Meeting August 23, 2019

Example: Support for PCCP Design Decisions

The map shows a network of pipes with several key design decisions highlighted: 'Raise HGL to 690' d/s of Venice PCS', 'Increase size of bottlenecks', 'Interconnection Valves', 'Carbon Creek PCS DS Grade 660'', 'Oak Street PCS US Grade 500'', and 'Increase sectionalizing valve sizes'.

Member Agency Manager’s Meeting August 23, 2019

3. Infrastructure Reliability

Maintain facilities in state of readiness to ensure system deliveries

- Joint task between Engineering and Operations

A hierarchical diagram with 'Infrastructure Reliability (Asset Management)' at the top in an orange box. Below it are three yellow boxes: 'Maintenance Management', 'Seismic Resilience', and 'Infrastructure Protection Plan'. Under 'Maintenance Management' are two blue boxes: 'Routine Maintenance Monitoring & Inspection' and 'Computerized Maintenance Management System'. Under 'Infrastructure Protection Plan' are two blue boxes: 'Conditions Assessments' and 'Vulnerability Assessments'.

Member Agency Manager’s Meeting August 23, 2019

4. System Flexibility

Respond to short-term changes in water supply, water demands, and water quality; and meet member agency needs during planned or unplanned outages

- Operational Flexibility
 - Operational adjustments
 - Hydraulic modeling
- Delivery Flexibility
 - Demand-driven projects
 - System Reliability Study

Member Agency Manager's Meeting

August 23, 2019

Example: System Reliability Study

- Presented as part of the IAS
- Purpose
 - Identify areas in our system that are vulnerable to a loss of service from a 7-day outage
- Approach
 - Postulate a single component failure
 - Evaluate options to restore service
 - MWD capability to re-route water to impacted area
 - Member agency alternative connections to MWD
 - Member agency wells & surface storage
 - Member agency interconnections
 - Quantify effect

Member Agency Manager's Meeting

August 23, 2019

5. Emergency Response

The ability to respond to unplanned outages and restore service as quickly as practical.

- Addressed through:
 - Emergency Response Plan
 - System Security Planning
 - Business Continuity Plan
 - Information Technology Disaster Recovery Plan
 - Mutual aid agreements
 - Seismic Resilience Task Force

Member Agency Manager's Meeting

August 23, 2019

Examples: Emergency Response

- Metropolitan maintains its own manufacturing shop facilities to fabricate and repair equipment and roll steel pipe
- The capability of these facilities has recently been upgraded substantially in order to expedite urgent repairs
 - Has the ability to repair at least two large diameter pipe breaks simultaneously
- Workshops and exercises are conducted regularly, including simulations of major seismic events



Member Agency Manager's Meeting


August 23, 2019

California Aqueducts



Member Agency Manager's Meeting

California Dams and Reservoirs



Member Agency Manager's Meeting





Videos

- <https://www.youtube.com/watch?v=Ozle7tS1SgQ>
- <https://www.youtube.com/watch?v=8A1v1Rr2neU>

Member Agency Manager's Meeting

August 23, 2019



- LEGEND:**
- EXISTING 60" PCCR (PLR 96468, 1982)
 - PROPOSED 54" EARTHQUAKE RESISTANT DUCTILE IRON PIPE (ERDIP) PHASE 2 (BY LADWP) APPROXIMATELY - 6,800 ft
 - PROPOSED , 54" WELDED STEEL PIPE - PHASE 2 (BY OTHERS)
 - INSTALLED 54" WELDED STEEL PIPE - PHASE 1
 - CITY OF LOS ANGELES - BOUNDARY LINE
 - EDUCATIONAL INSTITUTION
 - RELIGIOUS INSTITUTION
 - WA WORK AREA
 - FAULTS



FOOTHILL TRUNK LINE

UNIT 3 - Phase 2

Construction Map



The Research of Repairing Method of Water Tank Leakage

Giunn-Shyong Shiu
Director of Public Works Department
Taiwan Water Corporation



台湾自来水公司
TAIWAN WATER CORPORATION

October 9, 2019

《OUTLINE》

- ✓ Overview of TWC
- ✓ Purpose of the study
- ✓ Causes and types of leakage
- ✓ Water tank leakage repair method
- ✓ Three typical repair cases
- ✓ Conclusion

TAIWAN WATER CORPORATION

Overview of TWC

TAIWAN WATER CORPORATION

Water Supply Area	10,800 (km ²)
Branches	12
User Number	6.87 millions
Water Supply Amount	8.63 millions (CMD)
Main Length	60,000 (km)
Number of Water Supply System	144
Number of Water Purification Plant	449
Number of Monitoring Station	3,200



Overview of TWC

- The risk of water resources development in Taiwan



Purpose of the study


- Strengthening water resources management and reducing the water leakage rate
- Water leakage from water supply systems generally occurs in pipeline facilities and distribution water tanks.



2019/12/27

Purpose of the study

- TWC has 1,686 distribution water tanks, with a total capacity 3.6M m³.




Purpose of the study

- Earthquake damage to the water tanks
- Large damage → Remolition and reconstruction



Causes and types of leakage


- Seam
- Joints : Construction joint, Expansion joint, Turning joint



Causes and types of leakage

Seam

- Temperature change crack
- Earthquake or uneven subsidence
- Rusting and displacement of reinforcing steel
- Honeycomb phenomenon



9

Causes and types of leakage

Perforation



Concrete quality

- The water tightness of concrete is not enough
- Bleeding phenomenon



10

Water tank leakage repair method

Summary of leakage type

Plate	Wall	Crack
<ul style="list-style-type: none"> • Construction joints • Expansion joints • Transition joints • Temperature change cracks • Earthquake or uneven subsidence • Steel rust, displacement • Honeycomb phenomenon • Perforation • Waterproof layer damage, deficiencies • Insufficient water tightness of concrete • Bleeding. 	<ul style="list-style-type: none"> • Construction joints • Expansion joints • Transition joints • Temperature change cracks • Earthquake or uneven subsidence • Steel rust, displacement • Honeycomb phenomenon • Waterproof layer damage, deficiencies • Insufficient water tightness of concrete • Bleeding. 	<ul style="list-style-type: none"> • Construction joints • Expansion joints • Transition joints • Temperature change cracks • Earthquakes or uneven subsidence • Steel bars rust, displacement • Honeycomb phenomenon

11

Water tank leakage repair method

Covering the waterproof layer




Cover with Fiber-Reinforced Plastic (FRP)

Use steel plate to cover



12

Water tank leakage repair method

Set the V-shaped groove to apply the waterproofing agent cement mortar.



Cracks are stopped by high-pressure grouting.

13

Water tank leakage repair method

Through the outer wall to fill the grout



Concrete deep osmosis coating agent




14

Water tank leakage repair method

Rubber bead with stainless steel plate




15

Water tank leakage repair method

Repair of cracks or expansion joints.

Processing site	Material type
Filler	PE rod, waterproof foam, expanded rubber strip
Caulk	Epoxy resin, polyurethane (PU) sealant
Surface strengthening	FRP, non-woven fabric, elastic rubber water stop, stainless steel plate
External processing	Elastic rubber water stop, elastic cement, stainless steel



16

Water tank leakage repair method

■ Repair materials must not affect water quality.

Potassium permanganate consumption ≤ 2mg/L

Residual chlorine reduction ≤ 0.7mg/L

Phenols ≤ 0.05 mg/L

Amine: no detection

Chromaticity ≤ 1 degree

Cyanide: no detection

Odor and taste: no abnormalities

Turbidity ≤ 0.5 NTU

Film coating dissolution

17

Water tank leakage repair method

■ Summary of repair method


Plate	Wall	Crack
<ul style="list-style-type: none"> Covering waterproof layer Internal coating waterproof coating Through the wall outside the curtain grouting Concrete deep osmosis coating agent 	<ul style="list-style-type: none"> Covering waterproof layer Internal coating waterproof coating Through the wall outside the curtain grouting Concrete deep osmosis coating agent 	<ul style="list-style-type: none"> Use V-shaped groove to apply waterproofing agent cement mortar High-pressure grouting to stop leakage Concrete deep-layer osmosis coating agent Rubber bead with stainless steel plate

18


Three typical repair cases

■ Yuchi 3,000 m³ distribution water tank repair


- Leakage at the bottom of the water tank.



1. FRP material



2. FRP laying and coating on water tank bottom




3. FRP laying and coating on water tank wall

19


Three typical repair cases

■ Salu 40,000 m³ distribution water tank repair


- The expansion joints were displaced




1. Removed the old joint filler material




2. Expansion joint cleaning




3. Epoxy resin filling and repair



4. Elastic sealant filling



5. Laying FRP as a protective layer.



6. Soft rubber plus stainless steel plate construction

20


Three typical repair cases

■ Liyutan 50,000 m³ distribution water tank repair


- The expansion joints were displaced and leaked




1. Disinfection before diving




2. sludge removal




3. Remove the old expansion joint filler



4. Expansion joint cleaning



5. New rubber stop strip installation



6. Bottom floor drilling



7. Grouting through the bottom plate


21

Conclusion

- The basis for the applicability of the repair method should be determined by the size of the crack, the degree of damage, the water supply conditions of the water tank.
- The expansion joint is often the main cause of leakage of the water tank. Designed into multiple tanks and reducing the setting of the expansion joints can reduce the probability of water leakage.
- For expansion joints setting, it should consider the common shear steel bars, water stops, and caulking materials.
- Repair materials should pay attention to the safety of water quality. The materials should be inspected and confirmed to not affect the drinking water quality before use.

22

Thank you



台湾自来水公司
TAIWAN WATER CORPORATION

23

The 11th CTWWA/JWWA/WRF Water System Seismic Conference

A study on the behavior of a multiple-layered, fully-structural cured-in-place pipe in ultimate limit state in earthquakes

Hiromasa ISHIZEKI
 Manager, Potable Water Products
 PALTEM, Ashimori Industry Co., Ltd.

Ashimori property and confidential

Agenda

1. **Introduction**
2. Characteristics of "Base Hose"
3. Verification of adhesive-backed hose's performance to accommodate joint displacement
4. Bending test on a fully-structural CIPP

Introduction – CIPP (Cured-in-place pipe)

Lining by inversion

CIPP liner

Before Lining After

Introduction – CIPP (Cured-in-place pipe)

CIPP installation

Introduction – CIPP, example of PALTEM

Before inversion

Extruded resin

Seamlessly woven polyester jacket

"Base Hose" (Waterproof)

Glass roving mat

"Outer" cloth

After inversion

Outer cloth

Glass roving mat (Strengthening layer)

Introduction – Industrial background

Seismic standards for trenchless pipe rehab

- **Sewer**
Level 1 & 2 classification and performance criteria for CIPP
- **Gas**
CIPP standardized for sealing purpose in earthquakes
- **Potable water**
CIPP installation records not enough for standardization

Introduction – past experiences

400 km of our liners were used in...

[CELLR ANGE], [分類名]

[CELLR ANGE], [分類名]

[CELLR ANGE], [分類名]

[CELLR ANGE], [分類名]

[CELLR ANGE], [分類名]

[CELLR ANGE], [分類名]

Non-anti-seismic joints

(Okabe, 2012)

Introduction – continuous studies

Last workshop...

- Survey proved past performance
- Pipe with CIPP behaved like continuous pipe
- Calculation method selected for CIPP


Study continues:

CIPP's behavior in bending displacement?

Agenda

1. Why we do this
2. **Characteristics of "Base Hose"**
3. Verification of adhesive-backed hose's performance to accommodate joint displacement
4. Bending test on a fully structural CIPP

"Base Hose" - Characteristics



Thickness	mm	1.5~2.0
Axial tensile strength	N/mm	210~270
Burst pressure	MPa	0.30~0.75
Elongation at break	Jacket	% 15
	Coating resin	% 400

10

"Base Hose" - functions

Base Hose : "Adhesive-backed hose" or "cured-in-place liner"

- JWWA
"Sealing material in-pipe installation method"
- ISO11295
"Class-C and Class-D of "Lining with adhesive-backed hose"

Manufacturing stage	<ul style="list-style-type: none"> ✓ Holding resin ✓ Protection for strengthening layer
Installation stage	<ul style="list-style-type: none"> ✓ Air inversion ✓ Steam cure
In-service	<ul style="list-style-type: none"> ✓ Conformance to drinking water quality ✓ Leak/corrosion prevention

11

"Base Hose" - functions




12

Agenda

1. Why we do this
2. Characteristics of "Base Hose"
3. **Verification of adhesive-backed hose's performance to accommodate joint displacement**
 - Dynamic axial tensile test
 - Bending displacement test
4. Bending test on a fully structural CIPP

Dynamic tensile test – Base Hose by itself



Sample	Internal pressure (MPa)	Joint separation (mm)	Amplitude (mm)	Frequency (Hz)	Number of displacement cycles	Results
1	0.50	100	±50	1.0	30	No leakage
2		100	±10	3.0	90	
3		100	±20	3.0	90	


14

Dynamic tensile test – Base Hose by itself



15

Bending test – Base Hose by itself



Sample	Internal air pressure (MPa)	Host pipe joint break		Max displacement		Result
		Displacement (mm)	Bending angle	Displacement (mm)	Bending angle	
1	0.33	32	2.2	150	15.1	No Leakage
2		13	0.9			
3		18	1.2			

16

Capability of Base Hose – observations

- **Base Hose used as ABH (CIPL) debonds in displacement**
- **Debonded section accommodates further displacement and maintain water-tightness**
- **This phenomenon improves host pipe joints**

Agenda

1. Why we do this
2. Characteristics of “Base Hose”
3. Verification of adhesive-backed hose’s performance to accommodate joint displacement
4. **Bending test on a fully-structural CIPP**

Bending test - fully structural CIPP with BH

Adhesive-backed hose

- Corrosion prevention
- No strength layer
- Accommodation to displacement

Fully-structural CIPP

- Structural rehabilitation
- Strength layer for structural performance & long-term performance
- Pullout prevention & accommodation displacement

Specification of the tested CIPP

Layer	Property	Unit	Value
Strength layer	Nominal Diameter	mm	300
	Thickness	mm	4.0
	Flexural strength (hoop)	MPa	230
	Flexural modulus (hoop)	MPa	13,000
	Tensile strength (hoop)	MPa	210
	Tensile modulus (axial)	MPa	9,500
Waterproof layer	Burst pressure	MPa	5.6
	Elongation at break	%	2.0
	Thickness	mm	1.3
	Elongation at break	%	15.0

Bending test - fully structural CIPP with BH

Expansion

Contraction

Fixed pipe

Unfixed pipe

Hydraulic jack 20-mm/min displacement



Butt joint

Steel pipe with CIPP $\Phi 300 \times 2 \text{ m} \times 2$

Sample	Internal pressure (MPa)	Strengthening layer at break		Base Hose at rupture		Leakage
		Load (kN)	Bending angle	Load (kN)	Bending angle	
1	0.75	591	11.5	100	12.5	Yes
2	0.55	251	10.0	53	16.0	Yes
3	0.40	362	10.0	-	16.0	No*

*Test aborted at max bending of apparatus

Bending test - fully structural CIPP with BH



Conclusions

Q&A

Base Hose in CIPP behaved equivalently to adhesive-backed-hose (or CIPL)

CIPP maintained strength up to 10° bending

Strength layer suppressed bending displacement in non-anti seismic joints

Multi-layered CIPP maintained watertightness up to certain displacement after strength layer ruptured

Further challenges still remain

Contact: Hiromasa Ishizeki

hiomasa_ishizeki@ashimori.co.jp

25

26



Review of TWC Emergency Response System for Hualien Earthquake Disaster

Presenter : Wu-Lung Lin
 2019.10
 Head of Engineering Department
 The Ninth Branch of Taiwan Water Corporation

Contents

- Introduction of water supply
- Overview of Hualien earthquake disaster
- Emergency response
- Review and recommendations
- Conclusion


Introduction of water supply



Hualien County,
The Ninth Branch


Item	9th branch (a)	TWC (b)	Ratio (a/b)
Geographical area (Km*Km)	4, 629	36, 193	12. 79%
Number of workers (people)	162	5, 686	2. 85%
Population served (people)	286, 000	18, 162, 000	1. 57%
Water supply (CMD)	117, 300	8, 810, 000	1. 33%
Pipeline length (Km)	1, 892	62, 369	3. 03%

Introduction of water supply




Overview of Hualien earthquake disaster


- The Hualien 0206 earthquake, occurred at 23:50 on February 6, 2018. The earthquake **scale was ML 6.2, MW 6.4**, and had a focal depth of 6.3 km.
- About **400 aftershocks were recorded** till February 11, averaging about **80 times a day**.



Overview of Hualien earthquake disaster

- **4 buildings** partially collapsed or were severely damaged, **3 piers** in Hualien Port were cracked, **39 roads** were damaged, **17 people** died, **295 people** were injured.
- Domestic water supply for **40,000 households** was affected from February 7, and fully restored on February 14.
- The pipelines, equipments near the Milun fault and the Lingding fault were seriously damaged.
- The most serious damage of the tap water is the **600mm steel pipe**, for the supply of Hualien city, attached to both sides of the Shangzhi Bridge, were disconnected, and the **500mm steel pipe** on Xinxing Road severely distorted.
- As of February 14, **731 repairs** were completed, and up to 1,950 repairs till April.





Emergency response

According to the "Guidelines for Emergency Response Team", "Standard Operating Procedures for Disaster Event", etc., the following emergency response procedures were carried out, and TWC staff went all out for restoration to mitigate public inconvenience as soon as possible.

- Establish the **Emergency response team**
- Strengthen **emergency procurement**
- **Efficient release** of news and information
- **Zone the leak area**
- Repair with heart and soul
- Enhancement of **communication channels**
- Optimize **customer service**
- Flexible setting of **water supply stations**
- Enhance **water tankers dispatch**
- Confirmation of restoration

Emergency response

- Establish the Emergency response team

At 0:40 on Feb. 7, the emergency response center was set up by TWC. All resources were led and dispatched by experienced personnel, including the former Chairman of TWC and now Chairman of CTWWA, **Chun-Ming Kuo**, the President of TWC, **Nan-Tzer Hu**, and the former Chief Engineer and now the vice-president, **Jia-Rung Lee**.

Emergency response

- Strengthen emergency procurement
 - Using properly with **support terms of contract**.
 - Drew up and signed negotiation procedure with **non-contract** manufacturers according to **government procurement laws and examples** on February 7 .

主旨：為本處107年2月6日花蓮地區發生規模6.0地震，導致管線破裂受損，影響供水安全，經本處緊急會同各工程行、施工廠商及廠商代表，於2月7日召開緊急會議，由本處副處長主持，各工程行、廠商代表及廠商代表出席，會議中由本處副處長說明目前管線破裂受損情形，並請各廠商代表於2月7日以前，將管線破裂受損情形，以書面方式向本處提出，以利後續處理。

說明：一、依據「政府採購法第105條第1項第2款」及「特別採購程序處理辦法第2條、第5條、第6條及第7條」規定辦理。
二、標名：107年2月6日23:50花蓮強震造成本處管線破裂。
三、辦理緊急採購之必要：本處管線破裂，影響供水安全，應儘速修復，以維護供水安全。
四、辦理緊急採購之程序：本處管線破裂，應儘速修復，以利供水安全。本處管線破裂，應儘速修復，以利供水安全。本處管線破裂，應儘速修復，以利供水安全。

Emergency response



- Efficient release of news and information

Release date	News, information contents
9:00, February 7	Location of water supply station.
14:00, February 10	Hualien 0206 earthquake, TWC water supply route map (7 routes).
16:00, February 10	Hualien 0206 earthquake, The list of water and electricity operators for the damage of the private facilities and leaks.
22:00, February 11	Check the inside of the house for leaks to avoid sudden increase in bills. (Check the red triangle of the meter rotate or not)
09:00, February 14	Hualien 0206 earthquake, Water supply fully restored.
09:00, February 17	The President is concerned about post-disaster recovery, and the Vice President personally encourages TWC.
17:00, March 9	Hualien earthquake disaster review, TWC thanks all walks of life for their support.

In order to let the people feel at ease, understand the **restore progress**, etc., press release is issued in appropriate time.

Emergency response

- Zone the leak area
 - From Feb. 7 to Feb. 23, the **leak detection members** came from all the branch of TWC (**80 people**), were sent to Hualien City as a key area to divide the area of responsibility and perform pipeline inspections and surveys at night.
 - 315 leaks on the ground and 350 leaks under the ground, a total of **665 leaks were detected**. And all of these were transferred to nearby leak-repairing manufacturers.

Emergency response

- Repair with heart and soul

During the repair process, **22 manufacturers** covering leak repair, leak detection, water supply monitoring, formed **29 groups of manpower**. In addition, 5 self-employed manpower of TWC for leak repair, did their best for 24 hours. As of **Feb. 14**, **731 pipe repairs** were completed, and water was **restored** to almost all customers.

一區	鴻鼎工程行有限公司 裕原企業有限公司	五區	玉豐水電工程行 永治工程行 維豐工程行有限公司
二區	祥智工程行有限公司	六區	樹亞工程行有限公司
三區	仲實工程行有限公司	七區	國盛水電有限公司 正文水電工程行有限公司
四區	南東工程行有限公司	八區	樹亞工程行有限公司 永利工程行有限公司
五區	翔安水電工程行	九區	正文水電工程行有限公司 大鵬水電工程行
六區	豪通工程行	十區	永利工程行有限公司
七區	弓銘企業有限公司	十一區	永利工程行有限公司
八區	歐志水管工程行有限公司 利合伯水電工程行有限公司	十二區	馬原工程行有限公司 美潤工程行有限公司
	萬基工程行有限公司		

Emergency response

- Repair with heart and soul



600mm steel pipe, under Shangzhi Bridge

Emergency response

- Repair with heart and soul




400mm pre-stressed concrete pipe, Zhongzheng Road

Emergency response

- Repair with heart and soul

From Feb. 6 to 14, the number of leak items was 731. The leaks of **PVC/P** reached up to **83.72%**, of which the number of **communication pipe** is **561 (76.74%)**.



Emergency response

- Enhancement of communication channels

- Setup the **JUIKER** group "0206 Hualien Earthquake" for **internal communication**.
- Setup the **LINE** group "0206 Pipeline Inspection and Repair", "Water Truck Group", etc., for **each team staff**.
- Setup the **LINE** group "HuaLien Water Supply Information", for **public communication**, and the county councilor, village mayors, public opinion representatives of all levels, etc., can receive instant information.



Emergency response

● Optimize customer service

Date	February 7	February 8	February 9	February 10	February 11	February 12	February 13	February 14
Number of entry	1039	1519	1442	731	716	622	452	358

- The Customer Service Center collected and analyzed all water shortage incoming calls and the respective location every **2 hours**, and announced the analytics in the "0206 Hualien earthquake" JUIKER group.
- The emergency response team could grasp the disaster situation and determined the **priority** for processing water supply stations, leak repair, etc.

24

Emergency response

● Optimize customer service

- Issues with the water **meter box components** would be handled immediately by the service staff.
- **User's internal issues** (eg. internal leaks, pumping motor failure, etc.) would be explained in detail.
- As for leaks from the outside which locations could not be confirmed, the leak prevention department would be notified to assist in **leak detection**.
- As the leak location was **confirmed**, the Hualien Water Treatment Plant would record and **dispatch for the repairs**.
- **End-to-end control** by the customer service system.

25

Emergency response

● Flexible setting of water supply stations

- The water supply station reached max of **45 stations**, and the locations could be changed according to the water supply situation.
- Priority was given to sending water to the **medical institutions**, and injecting water into the **basement reservoir of the building**, which could immediately improve the water demand and eliminate the hardship for people to transport water.
- At 14:30 on February 10, **7 water delivery routes** (refer to the garbage truck route) were started to meet the water demand.



26

Emergency response

● Enhance water tankers dispatch

- When a worker reported for duty, he was required to scan the **QR CODE** to **join the LINE group**.
- Locations of all Water Purification Station and water supply station were jotted down on **Google Maps**.
- These Google maps were then posted and shared in the LINE group notes, so everyone could **automatically navigate** after clicking.
- After the work was allocated, the driver could automatically navigate according to the assigned locations. Handover of work was also more **convenient from this approach**.



27

Emergency response

● Enhance water tankers dispatch

Water tankers dispatch was up to **49** a day, the traffic volume of water supply was up to **219 times** a day, and **980 times** for all. With the **assistance of technology**, we could handle water tanker dispatching in an orderly manner.




28

Emergency response

● Confirmation of restoration

By using the **water supply monitoring system**, the 9th branch of TWC could instantly understand the water pressure of the pipe network, **prioritize** maintenance and repair, **respond** to users, and issue **press releases**.



29

Emergency response

● Confirmation of restoration

- The **water supply status reporting system** on the website of TWC, which was developed after the earthquake, allowed all users to report the water supply situation at their **location**, such as **normal**, **low water pressure**, and **water shortage**. Such reports could be instantly displayed on the map in different **colors**.
- With this system, we can quickly understand the water supply situation from the **users feedback** in the event of a water supply disaster in the future




30

Emergency response

● Confirmation of restoration

The **WADA** (Water Advanced Data Analysis) system developed by the big data project team of TWC has achieved great results. In the future, it can be applied to the automated analysis of a large number of **DMAs**, and can detect leaks more effectively.



31

Review and recommendations

After the restoration, TWC held 2 meetings ,on March 9 and April 20. The following suggestions were made:

- **Record of emergency response:** special personnel or professionals should be hired to handle the recording of the catastrophic recovery process. The record will be used for news release and subsequent employee training.
- **Emergency Rehearsal:** In order to ensure a smooth operation of water supply, and to enhance each employee's awareness of disaster prevention and their ability of emergency response, the compound disaster situation should be simulated.



32

Review and recommendations

- **Increase manpower and complete GIS map inquiry APP:** When manufacturers come to support the repairs, not only maintenance personnel, but also **supervisors and operators should provide the support together**. This is required to complete the repair data in detail with photos. After the repair, manpower should confirm whether the water valve has been restored or not, and strengthen the drainage and exhaust operation. After the impact, operation manpower of the 9th branch has added 8 people in 2018. In addition, a **GIS inquiry APP** has been completed to facilitate instant query of the pipeline network map.
- **Distinguish the responsibility** of leak detection and repair personnel according to the **DMAs** of the network.

33

Review and recommendations

- **Construction of leak detection and repair system APP:** case explosion, should be managed by a system together with leak detection and repair for effectiveness. Furthermore, such system can promote the efficiency of our customer service center with **value-adding applications**, such as combined water outage areas, instant pressure return, etc.
- Continue to build pressure observation stations and **strengthen monitoring system maintenance**.
- **Avoid important valve be undergrounded:** Due to the road leveling project, the road management department asked the pipeline company to bury the valve and the hole cover under the ground. It **increases the digging time** and the leak detection operation **cannot be tested by sections**, which will seriously affect the repair efficiency.

34

Review and recommendations

- Provide **accurate water repair estimation** to avoid public grievances.
- Introduce **local resources** to assist: For example, the water truck can be assisted by local **residents**; small repairs to the water meter box components can be assisted by local **technicians**; and customer service calls can be answered by **volunteers**.
- Introduce the ductile cast iron pipe with seismic joint (**NS-type DIP**):The NS-type DIP developed in Japan have **performed well** in many earthquakes. However, the current low demand in Taiwan leads to **high costs**, and it can only be piloted in high-potential areas with frequent **earthquakes** and **liquefaction** to improve the seismic resistance. And it will be **piloted in both Tainan and Hualien from 2019**.

35

Conclusion

- During the repair period, **experienced commanders** of TWC such like **Chun-Ming Kuo** (former chairman), **Nan-Tzer Hu** (president), **Jia-Rung Lee** (vice-president), led the team and dispatched all the resources to the recovery work.
- **49** water tankers, **29** manufacturers assisted the repair, over **500** people were mobilized, **45** water supply stations were set up, **7** routes were launched in the water shortage areas, and water trucks were dispatched to provide water injection service to basement reservoir of buildings.
- **Without taking any break** during the **Chinese New Year**, all the team did their best to **minimize public inconvenience**.

36

Conclusion

- Through **various countermeasures** and good use of technology tools, the water supply restored quickly. TWC reduced complaints and won applause.
- This is **all credited to the people and companies for their concern and assistance** during the restoration.
- We believe, with continuous **review and response improvement** after each disaster, TWC will become stronger.

37







Mitigation of Fault Displacement and Ground Subsidence for Large Diameter Pipeline

Tao Peng, P.E., S.E.
Cathy Chau, P.E.
Metropolitan Water District of Southern California


Presentation Outline

- Introduction
- Background
- Geologic Hazard Evaluation
- Seismic Design Criteria
- Mitigation Strategy
- Numerical Modeling
- Conclusions





Background

- 148-in concrete pipe constructed in 1935
- Ground subsidence due to ground water withdrawal
- Leaks have recurred for over 50 years
- Multiple repairs to address leaks
 - 300 ft of concrete pipe replaced with steel pipe in 1968
 - Internal seals installed in 1996 and 2017



Background


- Ground Subsidence
 - 5 feet of settlement in 800 feet
 - 0.8-in/year settlement adjacent to the Casa Loma Fault
- Casa Loma Fault (San Jacinto Fault System)
 - Capable of producing 7+ magnitude EQ
 - Potential displacement
 - 1 foot if fault ruptures on its own
 - 13 feet if multiple reaches rupture


Geo-Hazard Characterization Study

- Logic Tree Approach
 - Capture uncertainties in primary parameters
 - Tree branches represent values of parameters
 - Weights define distribution of values
- Fault Displacement Parameters
 - Rupture sources ←
 - Slip rate
 - Rupture length
 - Earthquake magnitude & recurrence
 - Fault displacement prediction model


Logic Tree Example – Rupture Sources



Logic Tree Example – Fault Source



Logic Tree Example – Prob. Fault Displacement



Seismic Design Criteria

- Estimated Fault Displacement

Deterministic (DFDHA)	Horizontal	Vertical
50 th percentile	4.8 feet (1.46 meters)	1.0 foot (0.3 meter)
84 th percentile	14.2 feet (4.33 meters)	2.9 feet (0.9 meter)
Probabilistic (PFDHA)	Horizontal	Vertical
975 years (5% in 50 years)	5.9 feet (1.8 meters)	1.2 feet (0.4 meter)
2475 years (2% in 50 years)	12.8 feet (3.9 meters)	2.6 feet (0.8 meter)

- Estimated Non-Tectonic Settlement

- Settlement rate 0.8-in/year
- Total 5 feet for 75 years

- Total displacement = Fault displacement + Settlement


Mitigation Strategy

- Earthquake Resistant Ductile Iron Pipe (ERDIP)
 - Absorbs large displacements & allows pipeline to remain intact
 - Over 50 years of experience in Japan
 - Used in US and Canada since 2013




Project Scope


- Replace approx. 1000 feet of 148-in diameter steel and concrete pipe at fault crossing
 - Dual barrels of 104-in diameter ERDIP
 - Designed to withstand 13 feet horizontal and 3 feet vertical fault displacement plus 5 feet ground subsidence




ERDIP Joint Modeling




Joint behavior: Moving in tension




Joint behavior: Locking in tension




Joint behavior: Rotation




Joint behavior: Locking in rotation




Joint behavior: Locking in rotation and tension



Axial/rotation joint capacity with and without interaction




ERDIP Joint Modeling



Pipeline and Fault Interaction Modeling


- Optimization of the modeling using EPS GeoFoam as backfill material



ERDIP Performance Testing



Revised Rotation Spring



Conclusions

- The displacement hazard would cause large stresses in a conventional continuous pipeline.
- ERDIP absorbs the displacement through axial movement and rotation within the joints.
- The pipeline system could be designed for large displacement with a combination of S-type joints, collar joints, and engineered backfill.



Questions?

